



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx CML 15.0063X

Issue No: 1

Certificate history:

Issue No. 1 (2017-10-13)

Issue No. 0 (2017-01-30)

Status: **Current**

Page 1 of 4

Date of Issue: **2017-10-13**

Applicant: **Braun GmbH**  
Esslinger Straße 26  
DE 71334 Waiblingen  
**Germany**

Equipment: **Isolating Amplifier D461**  
*Optional accessory:*

Type of Protection: **Intrinsic safety**

Marking:  
[Ex ia Ga] IIC  
Tamb: -20 °C to +50°C

*Approved for issue on behalf of the IECEx  
Certification Body:*

A Snowdon

*Position:*

Certification Officer

*Signature:  
(for printed version)*

*Date:*

October 13, 2017

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**Certification Management Limited**  
Unit 1, Newport Business Park  
New Port Road  
Ellesmere Port  
CH65 4LZ  
United Kingdom





# IECEX Certificate of Conformity

Certificate No: IECEx CML 15.0063X

Issue No: 1

Date of Issue: **2017-10-13**

Page 2 of 4

Manufacturer: **Braun GmbH**  
Esslinger Straße 26  
DE 71334 Waiblingen  
**Germany**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0

**IEC 60079-11 : 2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/CML/ExTR15.0067/00](#) [GB/CML/ExTR17.0173/00](#)

Quality Assessment Report:

[DE/TPS/QAR12.0006/04](#)



# IECEx Certificate of Conformity

Certificate No: IECEx CML 15.0063X

Issue No: 1

Date of Issue: 2017-10-13

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The Isolating Amplifier D461 is an intrinsic safety associated apparatus for use in a safe area that provide power to external speed sensors from an isolating switching transformer and conditions the associated speed signals for electronic measurements, alarms, totalizers, or controllers using an opto-coupler circuit.

**See Annex for full description and Conditions of Manufacture**

**SPECIFIC CONDITIONS OF USE: YES as shown below:**

**See Annex for Specific Conditions of Use**



# IECEX Certificate of Conformity

Certificate No: IECEx CML 15.0063X

Issue No: 1

Date of Issue: 2017-10-13

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

### Issue 1

This variation introduces the following modifications:

1. Repositioning of fuses F1 and F2 in the circuit
2. Removal of fuse F4
3. Change of thyristor package
4. Change of capacitor values
5. Addition of a capacitor
6. Addition of 2 ferrite inductors
7. Addition of coating to 230V version
8. Modification to the PCB tracking

### Annex:

[Certificate Annex IECEx 15.0063X Iss 1.pdf](#)

**Annexe to:** IECEx CML 15.0063X Issue 1  
**Applicant:** Braun GmbH  
**Apparatus:** Isolating Amplifier D461



## Description

The Isolating Amplifier D461 is an intrinsic safety associated apparatus for use in a safe area. It provides power to external speed sensors from an isolating switching transformer and conditions the associated speed signals for electronic measurements, alarms, totalizers, or controllers using an opto-coupler circuit.

The non-intrinsically safe circuitry is powered by an isolating switching transformer and monitors the speed sensor supply circuit for lead faults and annunciated by an alarm relay. The enclosure of the Isolating Amplifier D461 is designed to be installed on a DIN rail and meets the requirements of environmental protection IP 20.

## Nomenclature:

|      |    |   |    |   |   |
|------|----|---|----|---|---|
| D461 | R1 | . | ** | U | * |
| A    | B  |   | C  |   | D |

Where

|     |      |  |
|-----|------|--|
| A = | D461 | Type of Device   |
| B = | R1   | Release 1  |
| C = | 11   | Device one signal channel input, one signal channel output.          |
|     | 12   | Device one signal channel input, two signal channel output parallel. |
|     | 21   | Device two signal channel input, two signal channel output           |
| D = | 1    | Supply Voltage 18 to 40 Vac/dc                                       |
|     | 2    | Supply Voltage 85 to 250 Vac   |

## Ratings:

### IS Sensor Outputs:

|  |        |        |                 |
|--|--------|--------|-----------------|
| Terminals:   | S1/4   | 22     | Signal 2        |
|  | S1/3   | 23     | Signal 1        |
|  | S1/2   | 24     | +Sensor Feed    |
|  | S1/1   | 25     | GND/Sensor Feed |
| Uo:  | 8.7 V  |        |                 |
| Io:  | 64 mA  |        |                 |
| Po:  | 384 mW |        |                 |
| Lo:  | IIC    | 7.9 mH |                 |
|  | IIB    | 38 mH  |                 |
| Co:  | IIC    | 5.9 µF |                 |
|  | IIB    | 50 µF  |                 |
| Note: Combined Lo and Co for Signal 1 and Signal 2 |        |        |                 |

Unit 1, Newport Business Park  
New Port Road  
Ellesmere Port  
CH65 4LZ

**T** +44 (0) 151 559 1160  
**E** info@cmllex.com

**www.cmllex.com**

Company Reg No. 8554022 VAT No. GB163023642



### Power Supply:

|           |       |   |   |
|-----------|-------|---|---|
| Terminals | S3/1  | 1 | L |
|           | S3/2  | 2 | N |
| Um (U1):  | 60 V  |   |   |
| Um (U2):  | 250 V |   |   |

### Signal Outputs

|            |      |    |                    |
|------------|------|----|--------------------|
| Terminals: | S2/1 | 10 | Output reference   |
|            | S2/2 | 11 | Signal Output 1    |
|            | S2/3 | 12 | Signal Output 2    |
|            | S2/4 | 13 | Logic Alarm Output |
| Um:        | 60 V |    |                    |

### Signal Outputs

|                 |             |   |                    |
|-----------------|-------------|---|--------------------|
| Terminals:      | S3/3        | 6 | Relay Alarm Output |
|                 | S3/4        | 8 | Relay Alarm Output |
| Um:             | 60 V        |   |                    |
| Relay Contacts: | 30 Vdc, 2 A |   |                    |

### Conditions of Certification

The following conditions relate to safe installation and/or use of the equipment.

- The values of  $C_o$  and  $L_o$  apply when one of the two conditions below is given:
  - The total  $L_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $L_o$  value, or
  - The total  $C_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $C_o$  value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- The total  $L_i$  of the external circuit (excluding the cable)  $> 1\%$  of the  $L_o$ , and
- The total  $C_i$  of the external circuit (excluding the cable)  $> 1\%$  of the  $C_o$ .

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than 1  $\mu$ F for IIB and 600 nF for IIC.



## Conditions of manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

1. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
2. IEC 60079-11:2011 CL 11.2 Routine Tests for Infallible Transformers All transformers are shall subjected to following routine verification and test voltages:
  - 2,500 V, between input and output windings;
  - 1,000 V between all the windings and the core;
  - 1,500 V between each winding which supplies an intrinsically safe circuit and any other output winding;

The test voltage shall be applied for a period of at least 60 s.

Alternatively, the test may be carried out at 1,2 times the test voltage, but with reduced duration of at least 1 s.

The applied voltage shall remain constant during the test. The current flowing during the test shall not increase above that which is expected from the design of the circuit and shall not exceed 5 mA r.m.s. at any time. During these tests, there shall be no breakdown of the insulation between windings or between any winding and the core or the screen.